

**Corrigendum-I**  
**IMPORTANT NOTICE**

Following modification were made in e-Tender NO. GMDC GVT/RAJPARDI/ELECT./CSR/02/2020-21 for the Supply & Installation of 36 W LED Street Lights in core zone villages of our Rajpardi project under CSR.

Sr	Clause No. in Tender Document	Page No. in Tender Document	Description	Revised Description
1	Chapter No. V, Clause No. 1 Sr.No.1	26	36 Watts LED Street Light fitting pipe mounted with complete mounting arrangement of Reputed Make. Fitting should be water & dust proof, Input Volts-230 AC, 50Hz, PF- Greater than 0.90, Input Power – 36 W, Colour – White, Colour Temperature – 4000 K to 6500 K, CRI – More than 80, Beam Angle - > 150, Lumens - > 3500, Finishing – Powder Coated, Housing – Pressure Die Cast Aluminum, Ingress Protection – up to <b>IP 68</b> , Operating Temperature – from – 20 deg. To 60 deg. LED Driver – Constant Voltage and Current (Integrated).	36 Watts LED Street Light fitting pipe mounted with complete mounting arrangement of Reputed Make. Fitting should be water & dust proof, Input Volts-230 AC, 50Hz, PF- Greater than 0.90, Input Power – 36 W, Colour – White, Colour Temperature – 4000 K to 6500 K, CRI – More than 80, Beam Angle - > 150, Lumens - > 3500, Finishing – Powder Coated, Housing – Pressure Die Cast Aluminum, Ingress Protection – up to <b>IP 65</b> , Operating Temperature – from – 20 deg. To 60 deg. LED Driver – Constant Voltage and Current (Integrated).
2	Tender Notice	4	18.01.2021 up to 15.00 Hrs. on <a href="https://gmhc.nprocure.com">https://gmhc.nprocure.com</a> only and 18.01.2021 up to 15.00 Hrs. at Corporate office, Ahmedabad.	25.01.2021 up to 15.00 Hrs. on <a href="https://gmhc.nprocure.com">https://gmhc.nprocure.com</a> only and 25.01.2021 up to 15.00 Hrs. at Corporate office, Ahmedabad.
Similarly it is requested to read as IP65 in place of IP 68 wherever in the tender and typographical error is to be eliminated.				

**General Manager (Power)**